

**NR\_key\_name:** 374CC61F89C4B253852562990075F0C9  
**SendTo:** ALL  
**CopyTo:**  
**DisplayBlindCopyTo:**  
**BlindCopyTo:** CN=R ecord/O=ARRB  
**From:** CN=Tracy Shycoff/O=ARRB  
**DisplayFromDomain:**  
**DisplayDate:** 12/21/1995  
**DisplayDate\_Time:** 4:31:15 PM  
**ComposedDate:** 12/21/1995  
**ComposedDate\_Time:** 4:28:14 PM  
**Subject:** cold offices  
I know this is going to sound a little bit like "the sweater made the computer go wacky", but ...I have been instructed by the building maintenance folks that we SHOULD NOT be turning off our light switches. The light switches are tied into the heating units and when the switch is off, the units blow cold or room temperature air instead of heated air. All lights that are tied to sensors (all but the round units in the reception area and the conference room) should be left on by their switches and controlled by the sensors.Let's give it a try and see if it makes a difference. Thanks.  
**Body:**  
**recstat:** Record  
**DeliveryPriority:** N  
**DeliveryReport:** B  
**ReturnReceipt:**  
**Categories:**